

M1 AutomationBridge Updates

From time to time there maybe software or firmware updates for the Ness M1 AutomationBridge.


The software / firmware can be updated within the Ness M1 AutomationBridge.

An active internet connection is required for the firmware update to complete.

Login to the Ness M1 AutomationBridge to begin the firmware update. If you are unsure of the IP address of the Ness M1 AutomationBridge then you can open the website mybridge.skaro.com.au and login with your email and password that you used to setup the Ness M1 AutomationBridge.

Notification Message


After you login up the top right it will display a notification to let you know there is a firmware update available.



Simply click on this notification and it will take you to the update screen.


Manual Checking

You can manually check if there is a firmware update by clicking on the Menu icon up the top right and then selecting the 'About' icon from the list.




Click on the 'Check for Updates' button.

This will check the online server for any new updates.



If there is a new update available it will display a message letting you know.

Click on the 'Install Update' button to begin the update.



The firmware update will take approx 1-3 minutes depending on your internet connection.

Additional Information:

Customer Service

Phone: 1300 551 991 (M-F 8:30am – 5:00pm)

Email: customerservice@ness.com.au

YouTube: www.youtube.com/nesscorporation